

## 生物柴油指标要求

PROPERTY	RESULT	TEST METHOD
Viscosity@40 C / (mm <sup>2</sup> /sec)	1.9-6.0	D445
Density@20 C	0.820-0.90	ASTM D4052
Flash Point / C	130min	D93
Sulfur Content / %	0.0015max	D5453
Carbon Residue / %	0.05max	D4530
Sulfated Ash / %	0.02max	D874
Water & Sediment / % vol.	0.05max	D2709
Mechanical Impurities	N/A	
Copper Strip Corrosion 50C. 3h	1	GB/T 5096
Cetane	49min	GB/T386
Oxidation Stability / (110C) / h	6.0min	EN14112
Acid Number / mg KOH/g	0.5max	D664
Free glycerin / %	0.02max	ASTM D6584
Total glycerin / %	0.24max	ASTM D6584

原文地址：<http://www.china-nengyuan.com/tech/103378.html>